

Project: Welding/Lawn Equipment Repair Shop A/C Replacement Addendum No. 2

Date: February 16, 2021

Owner: Cumberland County Schools 801 Gillespie Street Fayetteville, N.C. 28306

Bid Date: February 19, 2021 Bid Time: 10:00 a.m.

The following changes, additions and clarifications are made to the General Conditions and Specifications for the above referenced project. **Number of pages 1**

Exhaust fan Instillation

1. Contractors are to install a new working exhaust fan with a minimum 1150

cfm and two louvers with dampers. The louvers will be installed high on the rollup doors. The exhaust fan will be installed on the back wall. The fan will be wired to come on with the lights. The contractor is responsible for all wiring and permits. All work shall be done to local codes.

END OF ADDENDUM NO. 2