



Blane Hunt
Planning and Construction Coordinator
Operations Center

Phone: (910) 678-2557
Fax: (910) 678-7043
email: blanehunt@ccs.k12.nc.us

EMAIL COVER SHEET

Date: **December 20, 2022**

Attention: **Bidders**

Company: **See Below**

Regarding: **Cape Fear High School Lift Station Replacement**

Number of pages including this one: 2 Original will follow.

Comments:

Attached you will find the Addendum No. 1 for the above referenced project.

Carolina Lift Stations, Inc.: cframe@clsyork.com lpeabody@clsyork.com

Haire Plumbing Company: gene@haireplumbing.com

Locke-Lane Construction: arnn@aol.com

L.R. Thomas and Sons, Inc.: johnjr@lrthomasandsons.com

S & L Contracting, LLC: trent@sandlcontractingllc.com

Smith's Refrigeration, Inc.: ricksponce@smithsrefrigeration.com

Tencarva Machinery Company: sedwards@tencarva.com

Please give me a call if you have any questions.

Signed: _____


Blane Hunt

Confidential and Privileged: The information contained in this facsimile is privileged and confidential information intended for the sole use of the addressee. If the reader of this facsimile is not the intended recipient or the employee or agent responsible for delivering it to the intended recipient, you are hereby notified that any dissemination, distribution, or copying of this correspondence is strictly prohibited. If you have received this FAX in error, please immediately notify the sender, and return the original message by mail to the sender at the address listed below.

Mailing Address: 810 Gillespie Street, Fayetteville, North Carolina 28306



**Project: Cape Fear High School
Lift Station Replacement**

**Addendum No. 1
Date: December 20, 2022**

**Owner: Cumberland County Schools
810 Gillespie Street
Fayetteville, N.C. 28306**

**Bid Date: January 12, 2023
Bid Time: 10:00 AM**

The following changes, additions and clarifications are made to the General Conditions and Specifications for the above referenced project. **Number of pages 1**

Pre-Bid Conference

1. Review scope of work for the Lift Station Replacement.
2. Reviewed Time of Completion (30 days) the project is scheduled for the upcoming summer.
3. Reviewed the General Conditions and Supplementary General Conditions of the contract.
4. Contractor is to include a Miscellaneous Allowance of \$5,000.00 for in the Base Bid.
5. There is not a bond requirement on these projects.
6. Reviewed MBE Document requirement.
7. The Affidavit of Capital Improvement is included in the bid package.
8. Gorman Rupp Pump Station Mechanical Equipment includes: (2) T3C60SC-B/F, 3" Gorman Self-Priming Pumps with Eradicator Solids Management System, (2) V-Belt Drives, (2) 7.5, 3/60/460V, 1800 RPM ODP Motors, High Temperature Thermostats, (2) Gauge Kits, (4) Drain Kits, (1) Drain Hose, (2) GR 4" Check Valve, (1) Three Way Valve.
9. Gorman Rupp Duplex Control Panel: 7.5 HP, 3/60/460V, Allen Bradley FVNR Starters, (3) Float Control, Alarm Light, Alarm Horn, U.L. Listed, NEMA 1/Stainless Steel Enclosure.
10. Gorman Rupp 6 X 6 Tall Fiberglass Enclose with 4 Hinged Doors.
11. Questions about school schedule will follow at the first of the year.
12. Contractor is to remove all existing equipment from the site.
13. The Owner will review product lead time with the installation schedule.

END OF ADDENDUM NO. 1

Mailing Address: 810 Gillespie Street, Fayetteville, North Carolina 28306